

Skid Tanks vs. Temporary Tanks

Temporary tanks

Used in conjunction with construction projects

Not on a site for more than 12 months

Not permanently located on a site

Must have secondary containment

Must have protection from damage

Must have proper and accessible fire extinguishers



Fuel Tank at a construction site

Skid Tanks

Are acceptable to be used for a non-retail location, fleet refueling, only

Cannot exceed 1,000 Gallons for Class I liquids (Gasoline)

Cannot exceed 2,000 Gallons for Class II and Class III liquids (Diesel)

Must follow all other requirements for an AST



Skid tank at a non-resale location